



NOTE - ALL DIMENSIONS APPROXIMATE UNLESS OTHERWISE STATED

MAINTAIN 18" MINIMUM CLEARANCE ABOVE AND 12" MINIMUM CLEARANCE ON BOTH SIDES OF VALVE ACTUATOR FOR SERVICE.

ALL PIPE CONNECTIONS ARE 1/2" N.P. T.

DTV-050  
(1/2" NPT)