



NOTE - ALL DIMENSIONS APPROXIMATE UNLESS OTHERWISE STATED

MAINTAIN 18" MINIMUM CLEARANCE ABOVE AND 12" MINIMUM CLEARANCE ON BOTH SIDES OF VALVE ACTUATOR FOR SERVICE.

ALL PIPE CONNECTIONS ARE 1" N.P.T.

DTV-100
(1" NPT)